



Pump Stations 1500 Hours PMs

Hourly Year: 2010

1500 HOURS IN USE — CAN BE FROM 60-600 DAYS

Manhasset Valley

Dry Well

#1

#2

#3

Previous 37,500

Previous 43,000

Previous 40,500

Sewer Pumps

Grease Pump Bearings
(Every 1500 Hours)

Initial	Date
<u>1000</u>	<u>5/28</u>
<u>39,000</u>	<u>1000</u>

Initial	Date
<u>44,500</u>	<u>44,500</u>

Initial	Date
<u>1000</u>	<u>5/28</u>
<u>39,000</u>	<u>1000</u>

① New timers installed

TOP & BOTTOM BEARINGS

Initial	Date
<u>2500</u>	
<u>40,800</u>	

Initial	Date
<u>46,000</u>	

Initial	Date
<u>2500</u>	
<u>40,500</u>	

✓ checked 11/9/10
✓ 5/28/10
✓ 9/24/10
✓ 11/1/10

Lithium Based EP2 Grease

Initial	Date
<u>4000</u>	
<u>42,000</u>	

Initial	Date
<u>47,500</u>	

Initial	Date
<u>4000</u>	
<u>42,000</u>	

Initial	Date
<u>5500</u>	
<u>43,500</u>	

Initial	Date
<u>49,000</u>	

Initial	Date
<u>5500</u>	
<u>43,500</u>	

Bayview Pump House

Dry Well

#1

#2

#3

-Grease Pump Bearings
(Every 1500 Hours)
12 SHOTS/ OFF

Previous	Initial	Date
<u>9,985</u>	<u>11,485</u>	<u>5/28</u>
	<u>11,500</u>	

Previous	Initial	Date
<u>10,000</u>	<u>11,500</u>	<u>11,500</u>

Previous	Initial	Date
<u>9,924</u>	<u>11,424</u>	<u>11,500</u>

✓ 11/5/10
✓ 5/28/10
✓ 11/1/10
✓ due 12/10

Lithium Based EP2 Grease

Initial	Date
<u>12,985</u>	<u>12,908</u>

Initial	Date
<u>13,000</u>	<u>12,940</u>

Initial	Date
<u>12,924</u>	<u>13,014</u>

Initial	Date
<u>14,485</u>	

Initial	Date
<u>14,500</u>	

Initial	Date
<u>14,424</u>	

Initial	Date
<u>15,985</u>	

Initial	Date
<u>16,000</u>	

Initial	Date
<u>15,924</u>	