



# Pump Stations Quarterly PMs

Quarter: 1 2010

## Manhasset Valley ✓

### Main Floor

-Diesel Generator Kit

Initial Date  
VZ 1/19

-Panel Board

Initial Date  
VZ 1/19

Clean Battery Terminals

Blowers  
Change Filter

### Dry Well

-Valves

Initial Date  
VZ 1/19

Exercise

-Pumps & Check Valves

Initial Date  
VZ 3/1

-Pumps & Check Valves

Initial Date  
VZ 3/1

Inspect Pump Housing  
Make Sure to Clean

Inspect Check Valve  
Operation

② pumps and checks operating properly

### Wet Well

-Sluice Gates

Initial Date  
VZ 1/19

Exercise,

Clean Threads (Every 3 Months)

---

## Shelter Rock ✓

### Dry Well

-Valves

Initial Date  
VZ 1/19

Exercise

-Pumps & Check Valves

Initial Date  
VZ 3/19

-Pumps & Check Valves

Initial Date  
VZ 3/19

Inspect Pump Housing  
Make Sure to Clean

Inspect Check Valves  
Make Sure to Clean

① Pumps and checks operating properly

### Roof

-Clean Battery Terminals

Initial Date  
VZ 2/19

## Bayview Pump House ✓

### Main Floor

-Diesel Generator Kit

Initial Date  
VZ 2/19

-Reverse or Change

Initial Date  
VZ 2/25

Clean Battery Terminals

Filters

### Dry Well

-Pumps & Check Valves

Initial Date  
VZ 2/25

-Pumps & Check Valves

Initial Date  
VZ 2/25

Inspect Pump Housing  
Make Sure to Clean

Inspect Check Valves  
Make Sure to Clean

-Adjust Impeller #1

Initial Date  
VZ 2/25

-Adjust Impeller #2

Initial Date  
VZ 2/25

-Adjust Impeller #3

Initial Date  
VZ 2/25

Clearance

Clearance

Clearance

① Pumps and checks operating properly



# Pump Stations Quarterly PMs

Q1 2010

## Bayview Main House ✓

### Wet Well

#### -Well

Exercise Gate Valves

Initial	Date
VZ	2/19

- Value inoperable

#### -Pumps & Check Valves

Inspect Pump Housing

Initial	Date
VZ	2/19

Make Sure to Clean

#### -Pumps & Check Valves

Inspect Check Valves

Initial	Date
VZ	3/19

Make Sure to Clean

Pumps and checks operatus properly

### Outside

#### -Underground Valves

Initial	Date
VZ	3/19

### Bluebird Pumps

#### -Pumps & Check Valves

Inspect Pump Housing

Initial	Date
VZ	3/19

Make Sure to Clean

② pump and

#### -Pumps & Check Valves

Inspect Check Valves

Initial	Date
VZ	3/19

Make Sure to Clean

② checks operatus properly

## Grist Mill ✓

### Dry Well

#### -Sewer Pumps

Check Oil

Initial	Date
VZ	3/15

### Wet Well

#### -Valves

Exercise

Initial	Date
VZ	3/12

#### -Pumps & Check Valves

Inspect Pump Housing

Initial	Date
VZ	3/15

Make Sure to Clean

① Pumps and checks operatus properly

#### -Pumps & Check Valves

Inspect Check Valves

Initial	Date
VZ	3/15

Make Sure to Clean

## Greenleaf Hill

#### -Pump Pumps

and inspect

Initial	Date
VZ	3/31



#### -Debris in the

Impeller?

Yes

No

Date

#### -Grease Pump Rails

Initial	Date
VZ	2/31

#### -Check Oil Level

in Pumps

Initial	Date
VZ	3/31