



Pump Stations Quarterly PMs

Quarter: 2 2010

Manhasset Valley

✓

Main Floor

-Diesel Generator Kit

Initial Date
VZ 5/21

Clean Battery Terminals

-Panel Board

Initial Date
VZ 5/21

Blowers
Change Filter

Dry Well

-Valves

Initial Date
VZ 5/21

Exercise

-Pumps & Check Valves

Initial Date
VZ 5/21 (1)

Inspect Pump Housing
Make Sure to Clean

-Pumps & Check Valves

Initial Date
VZ 5/21 (1)

Inspect Check Valve
Operation

(1) Pumps and checks working properly

Wet Well

-Sluice Gates

Initial Date
VZ 5/21

Exercise

Clean Threads (Every 3 Months)

Shelter Rock

✓

Dry Well

-Valves

Initial Date
VZ 5/21

Exercise

-Pumps & Check Valves

Initial Date
VZ 5/21 (1)

Inspect Pump Housing
Make Sure to Clean

-Pumps & Check Valves

Initial Date
VZ 5/21 (1)

Inspect Check Valves
Make Sure to Clean

(1) Pumps and checks working properly

Roof

-Clean Battery Terminals

Initial Date
VZ 5/21

Bayview Pump House

✓

Main Floor

-Diesel Generator Kit

Initial Date
VZ 5/26

Clean Battery Terminals

-Reverse or Change

Initial Date
VZ 5/26

Filters

Dry Well

-Pumps & Check Valves

Initial Date
VZ 5/26 (1)

Inspect Pump Housing
Make Sure to Clean

-Pumps & Check Valves

Initial Date
VZ 5/26 (1)

Inspect Check Valves
Make Sure to Clean

(1) Pumps and checks working properly

-Adjust Impeller #1

Initial Date
VZ 5/26

Clearance

-Adjust Impeller #2

Initial Date
VZ 5/26

Clearance

-Adjust Impeller #3

Initial Date
VZ 5/26

Clearance



Pump Stations Quarterly PMs

Q2 2010

Bayview Main House ✓

Wet Well

-Well

Exercise Gate Valves

Initial Date
VZ 5/26

splitter valve not closing

-Pumps & Check Valves

Inspect Pump Housing

Make Sure to Clean

Initial Date
VZ 5/24 ①

-Pumps & Check Valves

Inspect Check Valves

Make Sure to Clean

Initial Date
VZ 5/24 ①

① Pumps and Checks work properly

Outside

-Underground Valves

Initial Date
VZ 5/26

Bluebird Pumps

-Pumps & Check Valves

Inspect Pump Housing

Make Sure to Clean

Initial Date
VZ 5/24 ②

-Pumps & Check Valves

Inspect Check Valves

Make Sure to Clean

Initial Date
VZ 5/24 ②

② Pumps and Checks work properly

Grist Mill ✓

Dry Well

-Sewer Pumps

Check Oil

Initial Date
VZ 6/9

Wet Well

-Valves

Exercise

Initial Date
VZ 5/28

-Pumps & Check Valves

Inspect Pump Housing

Make Sure to Clean

Initial Date
VZ 5/28 ①

-Pumps & Check Valves

Inspect Check Valves

Make Sure to Clean

Initial Date
VZ 5/28 ①

① Pumps and Checks work properly

Greenleaf Hill ✓

-Pull Pumps

and Inspect

Initial Date
VZ 6/8



-Debris in the

Impeller?

Yes

No

Date

6/8

-Grease Pump Rails

Initial Date
VZ 6/8

-Check Oil Level

in Pumps

Initial Date
VZ 6/8