



Pump Stations Quarterly PMs

Quarter: 4 2010

Manhasset Valley ✓

Main Floor

-Diesel Generator Kit

Initial Date
VZ 11/5

Clean Battery Terminals

-Panel Board

Initial Date
VZ 11/19

Blowers
Change Filter

Dry Well

-Valves

Initial Date
VZ 11/5

Exercise

-Pumps & Check Valves

Initial Date
VZ 11/12

Inspect Pump Housing
Make Sure to Clean

-Pumps & Check Valves

Initial Date
VZ 11/12

Inspect Check Valve
Operation

① Pumps and checks working properly

Wet Well

-Sluice Gates

Initial Date
VZ 10/14

Exercise

Clean Threads (Every 3 Months)

Shelter Rock ✓

Dry Well

-Valves

Initial Date
VZ 11/8

Exercise

-Pumps & Check Valves

Initial Date
VZ 11/12

Inspect Pump Housing
Make Sure to Clean

-Pumps & Check Valves

Initial Date
VZ 11/12

Inspect Check Valves
Make Sure to Clean

① Pumps and checks working properly

Roof

-Clean Battery Terminals

Initial Date
VZ 10/14

Bayview Pump House ✓

Main Floor

-Diesel Generator Kit

Initial Date
VZ 11/9

Clean Battery Terminals

-Reverse or Change

Initial Date
VZ 11/15

Filters

Dry Well

-Pumps & Check Valves

Initial Date
VZ 10/15

Inspect Pump Housing
Make Sure to Clean

-Pumps & Check Valves

Initial Date
VZ 10/15

Inspect Check Valves
Make Sure to Clean

① Pumps and checks working properly

-Adjust Impeller #1

Initial Date
VZ 10/15

Clearance

-Adjust Impeller #2

Initial Date
VZ 10/15

Clearance

-Adjust Impeller #3

Initial Date
VZ 10/15

Clearance



Pump Stations Quarterly PMs

Q4 2010

Bayview Main House ✓

Wet Well

-Well

Exercise Gate Valves

Initial	Date
vr	10/14

-Pumps & Check Valves

Inspect Pump Housing

Initial	Date
vr	10/14

Make Sure to Clean

-Pumps & Check Valves

Inspect Check Valves

Initial	Date
vr	10/14

Make Sure to Clean

① Pumps & Checks working properly

Outside

-Underground Valves

Initial	Date
vr	10/14

Bluebird Pumps

-Pumps & Check Valves

Inspect Pump Housing

Initial	Date
vr	10/14

Make Sure to Clean

-Pumps & Check Valves

Inspect Check Valves

Initial	Date
vr	10/14

Make Sure to Clean

① Pumps and Checks working properly

Grist Mill ✓

Dry Well

-Sewer Pumps

Check Oil

Initial	Date
vr	10/14

Wet Well

-Valves

Exercise

Initial	Date
vr	10/14

-Pumps & Check Valves

Inspect Pump Housing

Initial	Date
vr	11/12

Make Sure to Clean

-Pumps & Check Valves

Inspect Check Valves

Initial	Date
vr	11/12

Make Sure to Clean

① Pumps and Checks working properly

Greenleaf Hill

-Pump Pumps and Inspect

and Inspect

Initial	Date
vr	11/12



-Debris in the

Impeller?

Yes

No

Date

11/12

-Grease Pump Rails

Initial	Date
vr	11/12

-Check Oil Level

in Pumps

Initial	Date
vr	11/12

Q