



Pump Stations Semi Annual PMs

Semi - Annual Months: January - June 2010

Manhasset Valley ✓

Outside

-Valves (Underground)

Initial Date

Exercise

vr 5/26

Bayview Pump House ✓

Wet Well

#1

#2

-Muffin Monitors

Initial Date

-Muffin Monitors

Initial Date

Adjust Cutters

vr 11/15 ① ②

Adjust Cutters

vr 11/15

① cutters worn ② new cartridge installed (factory exchange) 2/2010

Greenleaf Hill ✓

Dry Well

-Remove Grease

Initial Date

-Clean Influent

Initial Date

-Valves

Initial Date

vr 6/8 ①

Screens

vr 6/8

vr 6/8

Muffin Monster

Initial Date

-Tighten Bolts

vr 6/8

① No grease in well