



# Pump Stations Semi Annual PMs ✓

Semi - Annual Months: July - December 2010

## Manhasset Valley ✓

### Outside

-Valves (Underground)

| Initial | Date |
|---------|------|
| v2      | 8/20 |

2 valves stuck open  
1 valve not sealing

Exercise

## Bayview Pump House ✓

### Wet Well

#1

#2

-Muffin Monitors

| Initial | Date |
|---------|------|
| v2      | 8/20 |

-Muffin Monitors

| Initial | Date |
|---------|------|
| v2      | 8/20 |

Adjust Cutters

Adjust Cutters

## Greenleaf Hill ✓

### Dry Well

-Remove Grease

| Initial | Date |
|---------|------|
| v2      | 7/13 |

-Clean Influent

| Initial | Date |
|---------|------|
| v2      | 7/13 |

-Valves

| Initial | Date |
|---------|------|
| v2      | 7/13 |

Screens

Muffin Monster

| Initial | Date |
|---------|------|
| v2      | 7/13 |

-Tighten Bolts