



# Pump Stations Weekly PMs

Week of: 2/1/10 - 2/15/10

## Manhasset Valley ✓

### Main Floor

-Diesel Generator Kit  
Check Oil,  
Water, Battery Water

Initial	Date
V2	2/1

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
V2	2/1

Start	End	Hours
0900	0930	30

-Panel Board  
Blowers  
Check Operation

Initial	Date
V2	2/1

### Dry Well

-Air Compressors  
Drain Water from Tank,  
Check Operation

Initial	Date
V2	2/1

-Seal Water  
System  
Check Fill Valve, Alternate Lead Pump,  
Check Operation (42 PSI)

Initial	Date
V2	2/1

### Wet Well

-Comminutor  
Check Operation

Initial	Date
V2	2/1

## Shelter Rock ✓

### Main Floor

-Air Compressors  
Check Operation,  
Drain Water from Tanks

Initial	Date
V2	2/1

### Dry Well

-Sewer Pumps  
Check Purge Lines

Initial	Date
V2	2/1

-Sump Pumps  
Check Operation

Initial	Date
V2	2/1

### Roof

-Generator Kit  
Check Oil & Water

Initial	Date
V2	2/1

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
V2	2/1

Start	End	Hours
0950	1010	33

### Wet Well

-Well  
Check

Initial	Date
V2	2/1

#2 disconnected



# Pump Stations Weekly PMs

2/1/10 - 2/5/10

## Bayview Pump House ✓

### Main Floor

-Diesel Generator Kit

Check Oil,  
Check Level in Day Tank

Initial	Date
VJ	2/1

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VJ	2/1

Start	End	Hours
1400	1430	.5

### Dry Well

-Air Compressors

Drain Water from Tank

Initial	Date
VJ	2/1

-Seal Water System  
Alternate Lead Pump,  
Check Tank Fill Valve & Operating Pressure

Initial	Date
VJ	2/1

-Sewer Pumps

Check Purge Lines,  
Check Seal, Water Usage (runs at 25 psi)

Initial	Date
VJ	2/1

-Clear Debris in

Impellers

Initial	Date
VJ	2/1

## Bayview Main Building ✓

### Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial	Date
VJ	2/1

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VJ	2/1

Start	End	Hours
1400	1420	.25

### Basement

-Floor Drains

Pump Water

Initial	Date
VJ	2/1

-Boiler

Check Operation

Initial	Date
VJ	2/1

-Piping

Check for Leaks,  
Check Seal, Water Usage

Initial	Date
VJ	2/1

*boiler off line*

### Wet Well

-Muffin Monitors

Check Operation,  
Clean Debris in Channels

Initial	Date
VJ	2/1



# Pump Stations Weekly PMs

2/1/10 - 2/5/10

## Grist Mill ✓

### Main Floor

-Diesel Generator Kit

Check Oil & Water,  
Check Battery Water

Initial	Date
VR	2/1

-Exercise Engine a min

of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VR	2/1

Start	End	Hours
1100	1130	.5

-Pump Control Panel

Check Operation

Initial	Date
VR	2/1

### Wet Well

-Comminutor

Clean Debris in Housing

Initial	Date
VR	2/1

## Greenleaf Hill

### Dry Well

-Generator Kit

Check Oil & Water,  
Check Battery Water

Initial	Date
VR	2/1

-Exercise Engine a min

of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VR	2/1

Start	End	Hours
1310	1330	.23

-Sump Pump

Check Operation

Initial	Date
VR	2/1