



Pump Stations Weekly PMs

Week of: 2/8/10 - 2/12/10

Manhasset Valley ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Water, Battery Water

Initial	Date
VR	2/8

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
VR	2/8

Start	End	Hours
0900	0930	.5

-Panel Board

Blowers
Check Operation

Initial	Date
VR	2/8

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

Initial	Date
VR	2/8

-Seal Water

System
Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial	Date
VR	2/8

Wet Well

-Comminutor

Check Operation

Initial	Date
VR	2/8

Shelter Rock ✓

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

Initial	Date
VR	2/8

Dry Well

-Sewer Pumps

Check Purge Lines

Initial	Date
VR	2/8

-Sump Pumps

Check Operation

Initial	Date
VR	2/8

Roof

-Generator Kit

Check Oil & Water

Initial	Date
VR	2/8

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
VR	2/8

Start	End	Hours
0900	1010	.33

Wet Well

-Well

Check

Initial	Date
VR	2/8

#2 disconnected



Pump Stations Weekly PMs

2/8/10 - 2/12/10

Bayview Pump House ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial Date
VR 2/8

-Exercise Engine a min

of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
VR 2/8
Start End Hours
1100 1130 .5

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
VR 2/8

-Seal Water System

Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial Date
VR 2/8

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial Date
[] []

-Clear Debris in

Impellers

Initial Date
VR 2/8

Bayview Main Building ✓

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date
VR 2/8

-Exercise Engine a min

of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
VR 2/8
Start End Hours
1105 1135 .5

Basement

-Floor Drains

Pump Water

Initial Date
VR 2/8

-Boiler

Check Operation

Initial Date
VR 2/8

boiler off line

-Piping

Check for Leaks,
Check Seal, Water Usage

Initial Date
VR 2/8

Wet Well

-Muffin Monitors

Check Operation,
Clean Debris in Channels

Initial Date
VR 2/8



Pump Stations Weekly PMs

2/8/10 - 2/12/10

Grist Mill ✓

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
VZ	2/9

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
VZ	2/9

Start	End	Hours
0845	905	.5

-Pump Control Panel

Check Operation

Initial	Date
VZ	2/9

Wet Well

-Comminutor

Clean Debris in Housing

Initial	Date
VZ	2/9

Greenleaf Hill ✓

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
VZ	2/8

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
VZ	2/8

Start	End	Hours
1310	1230	.33

-Sump Pump

Check Operation

Initial	Date
VZ	2/8