



Pump Stations 1500 Hours PMs

Hourly Year: 2011

1500 HOURS IN USE --- CAN BE FROM 60-600 DAYS

Manhasset Valley

Dry Well

#1	#2	#3
Previous 1,000	Previous 44,500	Previous 1,000
Initial VR Date 3/15	Initial VR Date 3/15	Initial VR Date 3/15
Reading Required 2,500 Reading at time of Maintenance 2400	Reading Required 46,000 Reading at time of Maintenance 46200	Reading Required 2,500 Reading at time of Maintenance 2600

✓ 3/2011

-Sewer Pumps

Grease Pump Bearings
(Every 1500 Hours)

TOP & BOTTOM BEARINGS

Initial	Date	Initial	Date	Initial	Date
4,000		47,500	11-18	4,000	11-18
Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance

clock not working

Lithium Based
EP2 Grease

Initial	Date	Initial	Date	Initial	Date
5,500		49,000		5,500	
Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance
7,000		50,500		7,000	
Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance

Bayview Pump House

Dry Well

-Grease Pump Bearings
(Every 1500 Hours)
12 SHOTS/ OFF

#1	#2	#3
Previous 12,908	Previous 12,940	Previous 13,014
Initial VR Date 6/14	Initial VR Date 6/14	Initial VR Date 6/14
Reading Required 14,408 Reading at time of Maintenance 14500	Reading Required 14,440 Reading at time of Maintenance 14500	Reading Required 14,514 Reading at time of Maintenance 14500

✓ - 11/11/11
✓ - 6/14/11

Lithium Based
EP2 Grease

Initial	Date	Initial	Date	Initial	Date
15,908	11-28	15,940	11-15	16,014	11-28
Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance
17,408		17,440		17,514	
Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance
18,908		18,940		19,014	
Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance	Reading Required	Reading at time of Maintenance

14,500 pumps