



Pump Stations Semi Annual PMs

Semi - Annual Months: January - June 2011

Manhasset Valley ✓

Outside

-Valves (Underground)

Exercise

Initial	Date
v2	2/19

2 valves stuck open
1 valve not sealing

Bayview Pump House ✓

Wet Well

-Muffin Monitors

Adjust Cutters

#1	
Initial	Date
v2	1/11

-Muffin Monitors

Adjust Cutters

#2	
Initial	Date
v2	1/11

Greenleaf Hill ✓

Dry Well

-Remove Grease

Muffin Monster

-Tighten Bolts

Initial	Date
v2	5/2

Initial	Date
v2	5/2

-Clean Influent

Screens

Initial	Date
v2	5/2

-Valves

Initial	Date
v2	5/2

S.A. Pump Stations - 1 ✓

Greenleaf pumps