



Pump Stations Weekly PMs

Week of : 11/28/2011 - 12/2/2011

Pump Stations

Manhasset Valley

Main Floor

-Diesel Generator Kit

Check Oil,
Water, Battery Water

Initial Date
Bill 11-28

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
Bill 11-28
Start End Hours
1461 1461 30 min

-Panel Board

Blowers
Check Operation

Initial Date
Bill 11-28

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

Initial Date
Bill 11-28

-Seal Water

System
Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date
Bill 11-28

Wet Well

-Comminutor

Check Operation

Initial Date
Bill 11-28

Shelter Rock

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

Initial Date
Bill 11-28

Dry Well

-Sewer Pumps

Check Purge Lines

Initial Date
Bill 11-28

-Sump Pumps

Check Operation

Initial Date
Bill 11-28

Roof

-Generator Kit

Check Oil & Water

Initial Date
Bill 11-28

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
Bill 11-28
Start End Hours
409.5 409.8 20 min

Wet Well

-Well

Check

Initial Date
Bill 11-28



Pump Stations Weekly PMs

11/28/2011 - 12/2/2011

Bayview Pump House

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial Date
Bill 11-28

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
11-29 Bill
Start End Hours
12:40 12:49 20 min

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
Bill 11-28

-Seal Water System

Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial Date
Bill 11-28

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial Date
Bill 11-28

-Clear Debris in

Impellers

Initial Date
Bill 11-28

Bayview Main Building

Main Floor

-Blue Bird Court Generat

Check Oil and Water,

Initial Date
[] []

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
[] []
Start End Hours
[] [] []

OFF Line

Basement

-Floor Drains

Pump Water

Initial Date
Bill 11-28

-Boiler

Check Operation

Initial Date
[] []

OFF

-Piping

Check for Leaks,
Check Seal, Water Usage

Initial Date
Bill 11-28

Wet Well

-Muffin Monitors

Check Operation,

Clean Debris in Channels

Initial Date
Bill 11-28



Pump Stations Weekly PMs

11/28/2011 - 12/2/2011

Grist Mill

Main Floor

-Diesel Generator Kit

Initial Date

Bill 11/28

Check Oil & Water,
Check Battery Water

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date

Start End Hours

-Pump Control Panel

Initial Date

Bill 11/28

Check Operation

Wet Well

-Comminutor

Initial Date

Bill 11/28

Clean Debris in Housing

Greenleaf Hill

Dry Well

-Generator Kit

Initial Date

Bill 11/28

Check Oil & Water,
Check Battery Water

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date

Bill 11/28

Start End Hours

-Sump Pump

Initial Date

Bill 11/28

Check Operation